



NOTES :

1. Concrete blocking is to be formed to ensure accessibility to fittings and poured against undisturbed earth.
2. Fittings are to be completely wrapped with plastic, prior to pouring concrete.
3. Concrete to be minimum 3,000 psi. @ 28 days.



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

4" to 12" STANDARD TAPPING SLEEVE and VALVE ASSEMBLY

| | |
|-------------------------------|---------------------|
| SCALE: Not To Scale | DETAIL # 2513.02 |
| REVISION DATE: APRIL, 2014 | SHEET #: 1 of 1 |