



NOTES:

1. No discharge from blow-off should go directly into a creek. Dechlorinate discharge before it enters a body of water.
2. Provide erosion and sedimentation control for discharge.
3. Extend #12 AWG trace wire to the end line size pipe.



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

**TEMPORARY 2" BLOW-OFF
ASSEMBLY FOR MAINS UP TO 8"**

SCALE: Not To Scale	DETAIL # 2514.01
REVISION DATE: APRIL, 2014	SHEET #: 1 of 1