



NOTES :

1. Wedge action restrainer gland joint restraints may be used in lieu of rodding. See detail 514.06.
2. Hydrants to be placed with pumper nozzle facing the street or as otherwise directed by Town Engineer.
3. When valve box is placed outside of pavement, provide concrete stabilization pad per detail 513.03.
4. Minimum of (2) 3/4" diameter stainless steel rods. See detail 512.06.
5. Where hydrant is set behind guardrail, provide adequate horizontal separation as directed by fire department.
6. Fire hydrant to be oiled & greased and cap to be sprayed (Non-petroleum – based) after installation.
7. Fire hydrant pavement marker on C/L. See specification 02510, paragraph 2.3.6



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

**TYPICAL FIRE HYDRANT
STREETS with SIDE DITCH**

SCALE: Not To Scale	DETAIL # 2514.04
REVISION DATE: APRIL, 2014	SHEET #: 1 of 1