



**NOTES:**

1. Fire mains to be pressure tested at 200 PSI.
2. DDC May be located inside building with Town Engineer approval.



**TOWN of CLAYTON**

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

**FIRE MAIN  
DETAIL**

SCALE:  
Not To Scale

DETAIL #  
2 519.06

REVISION DATE:  
July, 2010

SHEET #:  
1 of 1