



NOTES:

1. Foundation stone shall be required when soil conditions are unsuitable. See detail C01.02.
2. An additional 1 inch depth of bedding material will be required for each additional 2 feet of trench depth in excess of 16 feet up to a maximum of 12 inches.
3. Haunching depth for flexible wall pipe (C900 PVC and SDR35) shall be outside pipe diameter + 1 inch. Haunching shall be thoroughly compacted #57 or #67 stone.
4. Where rock is encountered, refer to detail 511.03 for subgrade preparation.
5. For all force mains, embedment to be Type 1 or 2 as shown on detail 511.02.



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

SANITARY SEWER PIPE LAYING CONDITIONS

SCALE: Not To Scale	DETAIL # 2531.01
REVISION DATE: July, 2010	SHEET #: 1 of 1