



NOTES:

1. In wet well, use floats. Transducers not permitted.
2. Automatic dialer to have dedicated telephone line, arranged for by the contractor, and placed in the name of Town of Clayton for billing purposes. Auto dialer to be Raco Verbatim 8 channel minimum.
3. Pump Station lot to be deeded separate w/road frontage. Easements are not acceptable.
4. Future gravity connections to pump station shall be made to a manhole upstream and outside station site.
5. Provide vehicle access to one side of wetwell for maintenance of wetwell & pumps.
6. Ensure access is provided to utility easements either thru or outside and adjacent to station site.
7. A manhole shall be placed upstream & inside of fenced station site.
8. A building to house control panel may be substituted for NEMA 4 enclosure and rainhood. Building to include thermostatically controlled ventilation (fan and louver) and light. Building to be approved by town engineer.



TOWN of CLAYTON
USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

TYPICAL SUBMERSIBLE PUMP STATION SITE LAYOUT		SCALE: Not To Scale	DETAIL # 2 534.08
		REVISION DATE: July, 2010	SHEET #: 1 of 1