



NOTES:

1. 8" deep No. 57 stone or equal wrapped in non-woven geotextile filter fabric lightly compacted. Overlap fabric by minimum one pipe O.D.
2. 4" deep No. 57 stone or equal lightly compacted pipe bedding.
3. General backfill compacted to 90% Standard Proctor density in 6" maximum lifts.



TOWN of CLAYTON

USE WITH THE TOWN of CLAYTON STANDARD SPECIFICATIONS ONLY

**UNSUITABLE SUBGRADE TRENCH DETAIL
TYPE A (SEWER & STORM DRAINAGE)**

SCALE: Not To Scale	DETAIL # 2 C01.02
REVISION DATE: July, 2010	SHEET #: 1 of 1